MONTHLY
Inspection Checklist

SAFETY SYSTEMS

Exit & Emergency Lights

Per NFPA 101 v2021: 7.9.3.1.2

Y = yes if the exit/emergency light illuminated for 30 seconds on a push button test and shows no signs of physical damage

N = no if the exit/emergency light did **not illuminate** for 30 seconds on a push button test or shows signs of physical damage

Date: 12 columns = 1 YEAR

Location of Exit/Emergency Light												

For more information and additional checklists, scan the QR code.

Contact a Summit Fire & Security expert if you need assistance.
www.summitfiresecurity.com

SUMMIT FIRE & SECURITY