



Fire Sprinkler Control Valve

Per NFPA 25 v2023

Answer each line item with **Y = yes**, **N = no** or **NA = not applicable**

Location of Control Valve:

12 columns = 1 YEAR

Date:												
In normal open or closed position												
Sealed locked or supervised												
Valve is accessible												
PIV has correct wrenches												
Free from external leaks												
Signage provided												
Gauges not damaged												

Location of Control Valve:

Date:												
In normal open or closed position												
Sealed locked or supervised												
Valve is accessible												
PIV has correct wrenches												
Free from external leaks												
Signage provided												
Gauges not damaged												



For more information and additional checklists, scan the QR code.

Contact a Summit Fire & Security expert if you need assistance.
www.summitfiresecurity.com

