



Wet or Dry Chemical System

Per NFPA 17A v2021: 8.2.2 Wet Chemical | Per NFPA 17 v2021: 11.2.1.1 Dry Chemical

Answer each line item with **Y = yes**, **N = no** or **NA = not applicable**

Location of System:

12 columns = 1 YEAR

Date:												
The extinguishing system is in its proper location												
The manual actuators are unobstructed												
The tamper indicators and seals are intact												
The maintenance tag or certificate is in place												
No obvious physical damage or condition exists that might prevent operation												
The pressure gauge(s) have been inspected physically to ensure it is in the operable range												
The nozzle blow off caps are intact and undamaged												
The hazard has not changed, including replacement modifications and relocation of protected equipment												



For more information and additional checklists, scan the QR code.

Contact a Summit Fire & Security expert if you need assistance.
www.summitfiresecurity.com

