



Fire Department Connection

Per NFPA 25 v2023: 13.8.1

Answer each line item with **Y = yes**, **N = no** or **NA = not applicable**

Location of Fire Department Connection:

12 columns = 3 YEARS

| Date: | | | | | | | | | | | | |
|---|--|--|--|--|--|--|--|--|--|--|--|--|
| Visible and accessible | | | | | | | | | | | | |
| Couplings or swivels are not damaged and rotate smoothly | | | | | | | | | | | | |
| Plugs or caps are in place and undamaged | | | | | | | | | | | | |
| If caps or plugs are missing, interior is clear of obstructions | | | | | | | | | | | | |
| Gaskets are in place | | | | | | | | | | | | |
| Identification signs are in place | | | | | | | | | | | | |
| Check valve is not leaking | | | | | | | | | | | | |
| Automatic drain valve is in place and operating properly | | | | | | | | | | | | |
| Visible piping to fire department connection is undamaged | | | | | | | | | | | | |



For more information and additional checklists, scan the QR code.

Contact a Summit Fire & Security expert if you need assistance.
www.summitfiresecurity.com

