



Diesel Driven Fire Pump & Pump Room

Per NFPA 25 v2023: 8.2.2 & 8.3.1.1

Answer each line item with **Y = yes**, **N = no** or **NA = not applicable**

12 columns = 3 MONTHS

Date:												
Ran fire pump in no-flow condition for 30 minutes												
Pump room is maintaining at least 40 degrees F												
Ventilating louvers are free to operate												
Excessive water is not collecting on the floor												
Pump suction, discharge and bypass valves are fully open												
Piping is free of leaks												
Suction line pressure gauge is reading within acceptable range (Record PSI)												
Discharge line pressure gauge is reading within acceptable range (Record PSI)												
Suction reservoir has the required water level												
Wet pit suction screens are unobstructed and in place												
Steady drip out of packing glands												
Fuel tank is at least two-thirds full												
Controller selector switch is in auto position												
Case/Circulation Relief Valve discharges water while pump is running												
Batteries voltage readings are within range												
Batteries charging have readings within range												
All alarm pilot lights are off												
Engine time meter is reading												
Oil level in right angle gear drive is within range												
Crankcase oil level is within acceptable range												
Cooling water level is within acceptable range												
Electrolyte level in batteries is within acceptable range												
Battery terminals are free from corrosion												
Water jacket heater is operating												
Power to pressure maintenance (jockey) pump is provided												



For more information and additional checklists, scan the QR code.

Contact a Summit Fire & Security expert if you need assistance.
www.summitfiresecurity.com

